

# Model HI-3702

## Clamp-On Induced Current Meter

---



### User Manual

PN: #H-600070

August, 2022

Rev J

ETS-Lindgren Inc. reserves the right to make changes to any products herein to improve functioning or design. Although the information in this document has been carefully reviewed and is believed to be reliable, ETS-Lindgren does not assume any liability arising out of the application or use of any product or circuit described herein; nor does it convey any license under its patent rights nor the rights of others. All trademarks are the property of their respective owners.

**© Copyright 1995 - 2022 written permission from ETS-Lindgren Inc. All Rights Reserved. No part of this document may be copied by any means without written permission from ETS-Lindgren Inc.**

Trademarks used in this document: The *ETS-Lindgren* logo is a registered trademark of ETS-Lindgren Inc.; *Teflon* is a registered trademark of E. I. du Pont de Nemours and Company or its affiliates.

### Revision Record

MANUAL, HI-3702 | Part # H-600070 Rev J

Revision	Description	Date
	Initial Release	November, 1995
A	Updates	May, 1996
B	Update battery charger	June, 1997
C	Add CE label	June, 1997
D	Add Appendix A	January, 1998
E	Update battery charger specifications	August, 1999
F	Update contact information; reformat	February, 2006
G	Update frequency range; rebrand	February, 2009
H	Update to battery charger options; rebrand	February, 2021
J	Remove references to obsolete products	August, 2022

# TABLE OF CONTENTS

---

<b>NOTES, CAUTIONS AND WARNINGS</b>	<b>5</b>
<b>SAFETY INFORMATION</b>	<b>6</b>
<b>INTRODUCTION</b>	<b>7</b>
Standard Configuration . . . . .	.7
Optional Items. . . . .	.7
ETS-Lindgren Product Information Bulletin . . . . .	.8
<b>MAINTENANCE</b>	<b>9</b>
Battery Maintenance . . . . .	.9
Annual Calibration . . . . .	.9
Maintenance of Fiber Optics . . . . .	10
Replacement and Optional Parts . . . . .	10
Service Procedures . . . . .	10
<b>RANGES &amp; SPECIFICATIONS</b>	<b>11</b>
Ranges . . . . .	11
Specifications . . . . .	11
HI-3702 Typical Frequency Response . . . . .	12
<b>OPERATION</b>	<b>13</b>
Computer Controlled Data Logging . . . . .	15
Battery Charging. . . . .	15
Error Codes . . . . .	16
<b>FUNCTIONAL THEORY OF OPERATION</b>	<b>17</b>
<b>APPENDIX A: SERIES H-491198-36 BATTERY CHARGER</b>	<b>18</b>
Introduction. . . . .	18
Charging the Battery . . . . .	18
Charging Indicators. . . . .	18
Specifications . . . . .	19
Maintenance Recommendations . . . . .	19
Replacing the Fuse. . . . .	19

**APPENDIX B: TYPE 1738819 BATTERY CHARGER**

21

Introduction . . . . .

21

Charging the Battery . . . . .

21

Charging Indicators. . . . .

21

Specifications . . . . .

22

Maintenance Recommendations . . . . .

22

**APPENDIX C: EC DECLARATION OF CONFORMITY**

23




Hi-3702 Clamp-On Induced Current Meter. . . . .

23

Series H-491198-36 Battery Charger . . . . .

24

# NOTES, CAUTIONS AND WARNINGS







	<b>Note:</b> Denotes helpful information intended to provide tips for better use of the product.
	<b>CAUTION:</b> Denotes a hazard. Failure to follow instructions could result in minor personal injury and/or property damage. Included text gives proper procedures.
	<b>WARNING:</b> Denotes a hazard. Failure to follow instructions could result in <b>SEVERE</b> personal injury and/or property damage. Included text gives proper procedures.

\*All notes, cautions, and warnings will be located on the left column area of the page.



See the ETS-Lindgren **Product Information Bulletin** for safety, regulatory, and other product marking information

## SAFETY INFORMATION

	<p>See the ETS-Lindgren <i>Product Information Bulletin</i> for safety, regulatory, and other product marking information.</p>
	<p><b>Warning:</b> This is a Safety Class I product (provided with a protective earthing ground incorporated in the power cord). The mains plug shall only be inserted in a socket outlet provided with a protective earth contact. Any interruption of the protective conductor, inside or outside the instrument, is likely to make the instrument dangerous. Intentional interruption is prohibited. DO NOT defeat the earth grounding protection by using an extension cable, power cable, or autotransformer without a protective ground conductor.</p>
	<p><b>Caution:</b> Uninsulated voltage within the unit may have sufficient magnitude to cause electric shock. Therefore, it is dangerous to make any kind of contact with any parts inside this unit.</p>
	<p><b>Caution:</b> This instrument is shipped with a three-wire power cable, in accordance with international safety standards. When connected to an appropriate power line outlet, this cable grounds the instrument cabinet.</p>
	<p><b>Warning:</b> No operator serviceable parts exist inside. Refer servicing to qualified personnel. To prevent electrical shock, do not remove covers.</p>
	<p><b>Warning:</b> The battery charger incorporates parts, such as a switch and relay that potentially could produce sparks or arcs.</p> <p><b>Warning:</b> For indoor use only, do not expose to rain.</p>

## INTRODUCTION

The ETS-Lindgren **HI-3702 Clamp-On Induced Current Meter** measures the induced body current of individuals working in environments where radio frequency (RF) electromagnetic fields are present.

The HI-3702 is designed to meet the requirements of IEEE C95.1-1991 Standard for Safety Levels with Respect to Human Exposure to Radio Frequency Electromagnetic Fields, 3 kHz to 300 GHz.



**HI-3702 Clamp On Current Sensor & HI-4416  
Digital Readout/Control Unit**

IEEE C95.1-1991 defines the acceptable levels of RF-induced body current for the frequency range of 3 kHz to 100 MHz. The acceptable levels range from 3 mA for uncontrolled exposures at 3 kHz, to 200 mA for controlled exposures between 100 kHz and 100 MHz.

The accuracy of the HI-3702 provides a means for determining compliance. The unit is completely portable and self-contained, and is simple to set up and easy to operate. The rugged design can be used for measurements in environments such as:

- Induction heating facilities
- Industrial welding applications
- Broadcast transmitting and antenna locations

### Standard Configuration

- HI-3702 Clamp-On Current Sensor
- HI-4416 Digital Readout/Control Unit with fiber optic cable
- Series H-491198-36 Battery Charger/ Series 1737570 Battery Charger
- Carrying Case

### Optional Items

- HI-4413USB - USB to Fiber Optic Interface
- HI-4413P Fiber Optic Modem

## **ETS-Lindgren Product Information Bulletin**

See the ETS-Lindgren Product Information Bulletin included with your shipment for the following:

- Safety, regulatory, and other product marking information
- Steps to receive your shipment
- Steps to return a component for service
- ETS-Lindgren calibration service
- ETS-Lindgren contact information



## CAUTION

Before performing any maintenance, follow the safety information in the ETS-Lindgren Product Information Bulletin included with your shipment.

## WARNING

Maintenance of the HI-3702 is limited to external components such as any cables or connectors.



Do not open the HI-3702 housing. Warranty may be void if the housing is opened.

If you have any questions concerning maintenance, contact our ETS-Lindgren Customer Service.



Under normal operating conditions, recharging the battery is the only HI-3702 maintenance performed by the user.

## MAINTENANCE

Take care to keep dirt and moisture from getting inside the housing of the HI-3702 Clamp-on Induced Current Meter and on the coplanar surfaces of the ferrite core that are exposed when the clamp-on sensor is open.

Do not use high-pressure sprays, and under no circumstance should the unit be immersed in water or other liquid; the HI-3702 is not waterproof. Such actions void the warranty.

### Battery Maintenance

Maintaining the HI-3702 requires that the nickel-cadmium (NiCd) battery be properly charged and the battery condition monitored. The normal operational life of the battery (approximately 1000 charge/discharge cycles) is such that by the time the battery needs replacement; the HI-3702 will need recalibration; these tasks are performed by ETS-Lindgren. For information on calibration services, see Annual Calibration below.

For the steps to charge the battery, see page 15.

In case of damage to the battery that causes premature failure, the HI-3702 must be sent to ETS-Lindgren for battery replacement; replacement in the field is not possible. See Service Procedures on page 10 for information on returning the HI-3702 to ETS-Lindgren for service.

### Annual Calibration

See the *Product Information Bulletin* included with your shipment for information on ETS-Lindgren calibration services.



## WARNING

Before performing any maintenance, disconnect the fiber optic cables from the unit and turn off power.

Failure to perform these tasks may result in damage to either or both the fiber optic connectors cables.

## Maintenance of Fiber Optics

Fiber optic connectors and cables can be damaged from airborne particles, humidity and moisture, oils from the human body, and debris from the connectors they plug into. Always handle connectors and cables with care, using the guidelines as follows:

- When disconnecting fiber optic cables, apply the included dust caps to the ends to maintain their integrity.
- Before connecting fiber optic cables, clean the connector tips and also the in-line connectors.
- Before attaching in line connectors, clean them with moisture-free compressed air.

## Replacement and Optional Parts

The following are the part numbers for ordering replacement or optional parts for the HI-3702.

Part Description	Part Number
HI-3702 Fitted Carrying Case	H-491132
HI-4416 Digital Readout/Control Unit	HI-4416
Fiber Optic Cable, 2-meter	H-491106-02
Battery Chargers	H-491198-36; 1737570
HI-4413P Fiber Optic Modem	HI-4413P
USB to Fiber Optic Interface	HI-4413USB
12V Auto Lighter Power Cord	H-22270-1534D

## Service Procedures

For the steps to return a system or system component to ETS-Lindgren for service, see the *Product Information Bulletin* included with your shipment.

## RANGES & SPECIFICATIONS


### Ranges

<b>Autorange:</b>	1.00 mA–1.000 A
<b>Range 1:</b>	1.00 mA–10.0 mA
<b>Range 2:</b>	3.1 mA–31.6 mA
<b>Range 3:</b>	10.0 mA–100.0 mA
<b>Range 4:</b>	0.031 A–0.316 A
<b>Range 5:</b>	0.100 A–1.000 A

### Specifications

<b>Typical Frequency Response:</b>	9 kHz–70 MHz $\pm 2.0$ dB
<b>Linearity:</b>	$\pm 0.5$ dB  At lower levels, the linearity for Range 1 deviates within $\pm 0.5$ dB due to noise. The remaining ranges follow the ideal curve as shown for Range 2 in Typical Frequency Response on page 15.
<b>Fiber Optic Connectors:</b>	Standard FSMA
<b>Fiber Optic Cable:</b>	200 micron, Graded Index, Multimode, Max Length 1 Km
<b>Readout:</b>	HI-4416 Digital Readout/Control Unit
<b>Physical Specifications</b>	
<b>HI-3702 Inner Diameter:</b>	105.4 mm (4.15 in)
<b>HI-3702 Outer Diameter:</b>	171.4 mm (6.75 in)
<b>HI-3702 Height:</b>	72.6 mm (2.86 in)
<b>HI-3702 Weight:</b>	1.7 kg ( 3 lb 13 oz)
<b>HI-4416 Digital Readout/Control Unit:</b>	0.42 kg (14.8 oz)
<b>Cushioned Case:</b>	0.085 kg (3.0 oz)
<b>Fiber Optic Cable:</b>	0.071 kg (2.5 oz)
<b>Battery/Battery Charger</b>	
<b>Battery:</b>	3.6 VDC, 1400 mAh rechargeable nickel-cadmium (NiCd)
<b>Battery Charger:</b>	115/230 VAC, approximately one hour
<b>Battery Life:</b>	Approximately 5 hours of continuous operation per full charge.
<b>Environmental</b>	
<b>Humidity:</b>	5% to 95% relative humidity, non-condensing
<b>Operating Temperature:</b>	10°C–40°C (50°F–104° F)

## HI-3702 Typical Frequency Response



## CAUTION

Before connecting any components, follow the safety information in the ETS-Lindgren Product Information Bulletin included with your shipment.

If you use this equipment in a manner not specified by ETS-Lindgren, the protection provided by the equipment may be impaired.


Do not position the equipment so that it is difficult to connect cables to or disconnect cables from the back of the unit.

## OPERATION

### 1. Charge the battery

Before taking any measurements, charge the battery to maximum capacity. For the steps to charge the battery, see page 15.

The nickel-cadmium (NiCd) battery installed in the HI-3702 Clamp-on Induced Current Meter was charged prior to shipment; however, NiCd batteries can self-discharge to nearly zero capacity after two months.



Cable Connectors

The battery charger requires approximately one hour to charge the battery to maximum capacity. Under normal operation, a fully-charged battery should provide five hours of operation. If the battery fails to hold a charge or if a significant degradation in operational time occurs, you may need to replace the battery.

### 2. Connect the fiber optic cables.

Connect the fiber optic cable to the HI-3702 and to the HI-4416 Digital Readout/Control Unit. Follow the color coding on the fiber optic cable, the HI-3702, and the HI-4416.

### 3. Power on the HI-3702.

Turn on the HI-3702. It is equipped with a locking lever on/off switch. Pull the switch lever out before toggling it to the appropriate position.

### 4. Power on the HI-4416.

Turn on the HI-4416. See the HI-4416 user manual for more complete operating information.


### 5. Select the range.

Use the HI-4416 to select the range that is appropriate for the expected current levels to be measured. To select auto range, scroll through the ranges until **Range A** appears on the screen.

When auto range is enabled, the probe will scroll up to the next higher range when the reading displayed exceeds full scale. The probe will scroll down to the next lower range when the reading displayed is - 14 dB (20%) of the full scale reading for the current range. This will put the reading at approximately 2/3 of full scale of the next lower range. See the following Auto Range Readings Table and Auto Range Flow Diagram.

Range	- 20dB of full scale	Reading after scroll down	- 14dB of full scale; scroll down point	Full scale scroll up point	Reading after scroll up	Full scale reading
1	1 mA	7.2 mA		10 mA		10 mA
2	3.16 mA	20 mA	7.2 mA	31.6 mA	10 mA	31.6 mA
3	10 mA	72 mA	20 mA	100 mA	31.6 mA	100 mA
4	31.6 mA	200 mA	72 mA	316 mA	100 mA	316 mA
5	100 mA		200 mA		316 mA	1000 mA

Auto Range Readings Table



Auto Range Flow Diagram

## 6. Select averaging.

Use the HI-4416 to select **Instantaneous Readings** or **One-Second Averaging**. The HI-3702 collects a measurement approximately seven times per second. When the X-axis is selected, each measurement is sent to the display. When the Y-axis is selected, the one-second average of the measurements is displayed. The averaging algorithm stores the seven most recent measurements. Each time a measurement is taken, the algorithm drops the oldest value, adds in the new value, and then recalculates the average and sends the new average value to the display.


## 7. Attach the clamp-on current sensor.

Place the clamp-on current sensor on the arm or leg of the body under test and close the buckle. For accurate measurements, verify that nothing interferes with complete closure of the clamp-on current sensor. Make sure no clothing is caught between the coplanar surfaces of the ferrite core material or the aluminum housing.

Displayed readings that are less than 10% of the full scale reading for the selected range are not valid. When **Range 1** or **Autorange** is selected and there is no current passing through the current meter, a noise floor reading will display. This is a normal operating condition.

## Computer Controlled Data Logging

Software is available for the personal computer that simulates the HI-4416. For information on using the HI-4416 for data logging, see the HI-4416 manual.



The HI-3702 is connected for data logging as shown.

To connect the HI-3702 to a PC serial port, use the optional model HI-4413P and RS232 cable assembly (PN H-2239615). For connection to a PC USB port, use the optional model HI-4413USB (cable included).

### CAUTION

Never attempt to recharge a non-rechargeable battery.



If the battery has been through its normal life span of approximately 1000 charge/discharge cycles, return the HI-3702 to ETS-Lindgren for battery replacement and recalibration. For more information, see Battery Maintenance on page 9.

## Battery Charging

1. Turn off the HI-3702.
2. Connect the battery charger/wall transformer to an AC outlet.
3. Plug the charger jack completely into the CHARGE connector on the clamp on current sensor.

Allow approximately one hour for a full charge cycle. When charging is complete, the battery charger automatically goes into a trickle charge. It will remain in trickle charge mode until disconnected from the HI-3702.

4. When the charge cycle is complete, remove the charger jack from the CHARGE connector on the clamp-on current sensor.
5. Unplug the battery charger from the AC outlet.
6. Use the HI-4416 to verify that the battery is charged to approximately 3.8 VDC.

See the appendices for your model for complete information on the battery charger.

## Error Codes


If an error occurs, the probe will respond with one of the following strings. These strings begin with a colon and end with a carriage return.

Error	String
E01	Communication error (for example, overflow)
E02	Buffer full error; too many characters contained between the start character and carriage return sequence
E03	Received command is invalid
E04	Received parameter is invalid
E05	Hardware error (for example, EEPROM failure)
E06	Parity error
E9	Received command is invalid



## FUNCTIONAL THEORY OF OPERATION

Following is a functional theory of operation for the HI-3702 Clamp-on Induced Current Meter. The objective is to enhance user understanding of the theory behind the design to aid with the operation and maintenance of the HI-3702.



Theory of Operation

The HI-3702 is designed to measure RF induced current flowing through the ankles or arms of the body under test, even while walking or climbing. The fiber optically coupled readout/control unit does not perturb the measured RF field or the current distributions.

The sensor is a ferrite split core current transformer. The signal generated by the sensor is amplified by 10 dB to 50 dB depending on the range that is selected. There is 20 dB of linearity for each range. This signal is applied to a True RMS Thermal RMS to DC Converter. The DC voltage output of the True RMS Thermal RMS to DC Converter is applied to a 12 bit A/D converter. This digital representation of the DC voltage is read by the microprocessor, converted to a number that is representative of current being sensed, and transmitted through the fiber optic interface to the HI-4416 Digital Readout/Control Unit.

**Note:**

The HI-3702 Clamp-on Induced Current Meter contains a nickel-cadmium (NiCd) battery, and uses the Series H-491198-36 Battery Charger.

**CAUTION**

Before operating the Series H-491198-36 Battery Charger, see Safety Information on page 6.


**CAUTION**

Never attempt to recharge a non-rechargeable battery.

## APPENDIX A: SERIES H-491198-36 BATTERY CHARGER

### Introduction

The Series H-491198-36 Battery Charger is a dual power source battery charger. It charges 3.6 Volt 1400 mAH NiCd batteries and is powered by 120-240 VAC line power or 12.5 VDC. The H-491198-36 charger uses a  $-(dV)/(dT)$  negative delta V technique to determine when the battery is fully charged, which is typically one hour. With this technique, the charge state of the battery has no effect other than shortening the charge time.



Housed in a rugged enclosure, power enters the battery charger through a power entry module, which contains the fuses, or an optional cigarette lighter plug adapter. The front face of the battery charger displays LEDs that provide the operating status. The battery charger connects to the device being charged through a short cord terminated with a power jack.

An integrated circuit within the battery charger monitors the battery voltage and controls the charging functions according to the charge state of the battery.

### Charging the Battery

For the steps to charge a battery, see page 15.

### Charging Indicators

The following LEDs are located on the front of the battery charger:

- **POWER ON** (green)—Indicates the battery charger is connected to the AC power source.
- **NO BATTERY** (amber)—Indicates the battery charger does not detect a battery.
- **PENDING** (amber)—Indicates the battery charger detects a battery. Before fast charging can begin, the battery voltage must fall within predetermined acceptable limits. A pulse-trickle charge is provided to bring a depleted battery to a valid charge prior to fast charge.
- **CHARGING** (amber)—Indicates the voltage pre-qualification condition has been met, and fast charge has started.
- **COMPLETE** (green)—Indicates a fast charging peak voltage is detected. The Field Probe can remain connected to the battery charger indefinitely while in this maintenance mode.

## Specifications

Power	
Main:	IEC filtered AC power input module ; 110-240 VAC, 500 mA max, 50-100 Hz
Alternate:	Automobile cigarette lighter to 2 mm power plug adapter cord, 12.5 Vdc, 100 mA
Fuses:	250 Volt, 1.0 Amp, Type T (5 mm x 20 mm)
Output	
Open Circuit Voltage:	15 Vdc
Fast Charge Pending Current:	60 mA
Fast Charge Current:	1400 mA
Pulsed Trickle Charge Current:	50 mA
Output Voltage (During Fast Charge):	3–6 Vdc
Battery	
NiCd Battery:	3.6 Volt 3 Cell NiCd Battery, 1400 mAH (rapid charge cells, 1.2 Volts/cell)  ETS-Lindgren Part #491038
Environmental	
Operating Temperature:	10°C–40°C (50°F–104°F)
Humidity:	5% to 95% relative humidity, non-condensing

## Maintenance Recommendations

- Operate the battery charger with care.
- There are no user serviceable parts inside the battery charger. Opening the battery charger housing may void your warranty.

## Replacing the Fuse


If the battery charger fails to operate, check for a blown fuse inside the power entry module. A blown fuse must be replaced with the same value and type of fuse, or an unsafe condition may result. Use only 250 Volt, 1.0 Amp, Type T (5 mm x 20 mm) fuses.

To replace a fuse:

1. Two fuses are located in the fuse drawer in the power input module. Use a screwdriver to open the drawer.
2. The fuse towards the outside of the drawer is the spare. Remove the spare fuse from the module.

### CAUTION

Disconnect the battery charger from power before replacing a fuse.



3. Replace the blown fuse with the spare fuse.
4. Slide the fuse drawer back into the module. Make sure that the drawer snaps securely into its locked position.

**Note:**

The HI-3702 Clamp-on Induced Current Meter contains a nickel-cadmium (NiCd) battery, and uses the Type 1737570 Battery Charger.

**CAUTION**

Before operating the Series 1737570 Battery Charger, see Safety Information on page 6.


**CAUTION**

Never attempt to recharge a non-rechargeable battery.

## APPENDIX B: TYPE 1738819 BATTERY CHARGER

### Introduction

The Series 1738819 Battery Charger charges 3.6 Volt 1400 mAh NiCd batteries and is powered by 1719573 a 90-240 VAC wall mount power supply. The 1719570 charger uses a - (dV)/(dT) negative delta V technique to determine when the battery is fully charged, which is typically one hour. With this technique, the charge state of the battery has no effect other than shortening the charge time.



Housed in a rugged enclosure, power enters the battery charger through a rear entry jack. The top face of the battery charger displays LEDs that provide the operating status. The battery charger connects to the device being charged through a short cord terminated with a power plug.

An integrated circuit within the battery charger monitors the battery voltage and controls the charging functions according to the charge state of the battery.

### Charging the Battery

For the steps to charge a battery, see page 15..

### Charging Indicators

The following LEDs are located on the top of the battery charger:

- **POWER ON** (green)—Indicates the battery charger is connected to the AC power source.
- **NO BATTERY** (amber)—Indicates the battery charger does not detect a battery.
- **PENDING** (amber)—Indicates the battery charger detects a battery.

Before fast charging can begin, the battery voltage must fall within predetermined acceptable limits. A pulse-trickle charge is provided to bring a depleted battery to a valid charge prior to fast charge.

- **CHARGING** (amber)—Indicates the voltage pre-qualification condition has been met, and fast charge has started.
- **COMPLETE** (green)—Indicates a fast charging peak voltage is detected. The Field Probe can remain connected to the battery charger indefinitely while in this maintenance mode.

## Specifications

Power	
Main:	12VDC 100mA
Output	
Open Circuit Voltage:	15 Vdc
Fast Charge Pending Current:	60 mA
Fast Charge Current:	1400 mA
Pulsed Trickle Charge Current:	50 mA
Output Voltage (During Fast Charge):	3–6 Vdc
Battery	
NiCd Battery:	3.6 Volt 3 Cell NiCd Battery, 1400 mAH (rapid charge cells, 1.2 Volts/cell)  ETS-Lindgren Part #491038
Environmental	
Operating Temperature:	10°C–40°C (50°F–104°F)
Humidity:	5% to 95% relative humidity, non-condensing

## Maintenance Recommendations

- Operate the battery charger with care.
- There are no user serviceable parts inside the battery charger. Opening the battery charger housing may void your warranty.

## APPENDIX C: EC DECLARATION OF CONFORMITY

### Hi-3702 Clamp-On Induced Current Meter



#### Declaration of Conformity

We, ETS-Lindgren, L.P., 1301 Arrow Point Drive, Cedar Park, TX, 78613, USA, declare under sole responsibility that the:

Model/Part Number: HI-3702

Model/Part Name: Induced Current Meter

Date of Declaration: 30 June, 1999

to which this declaration relates, meets the requirements and is in conformity with the relevant EC Directives listed below using the relevant section(s) of the following EC harmonized standards and other normative documents;

**Applicable Directive(s):**

Electromagnetic Compatibility Directive (EMC) 89/336/EEC and its amending directives

**Applicable harmonized standard(s) and/or normative document(s):**

EN 50082-1:1992 Electromagnetic compatibility - Generic Immunity standard Part 1 Residential, commercial and light industry

EN 55011:1991 - Group 1 Class B Limits and methods of measurement of radio disturbance characteristics of industrial, scientific, and medical (ISM) radio-frequency equipment

**Authorized Signatories:**

ETS-Lindgren L.P.  
Bryan Saylor, General Manager

ETS-Lindgren L.P.  
James C. Psencik, Vice President of Engineering

The authorizing signatures on this Declaration of Conformity document authorizes ETS-Lindgren, L.P. to affix the CE mark to the indicated product. CE marks placed on these products will be distinct and visible. Other marks or inscriptions liable to be mistaken with the CE mark will not be affixed to these products.

ETS-Lindgren, L.P. has ensured that technical documentation shall remain available on premises for inspection and validation purposes for a period ending at least 10 years after the last product has been manufactured.

## Series H-491198-36 Battery Charger



### Declaration of Conformity

We, ETS-Lindgren, L.P., 1301 Arrow Point Drive, Cedar Park, TX, 78613, USA, declare under sole responsibility that the:

**Model/Part Number:** H-491198-36/ H-491198-48/ H-491198-72

**Model/Part Name:** Battery Charger series

**Date of Declaration:** 30 June, 1999

to which this declaration relates, meets the requirements and is in conformity with the relevant EC Directives listed below using the relevant section(s) of the following EC harmonized standards and other normative documents;

**Applicable Directive(s):**

Low Voltage Directive (LVD), 73/23/EEC and its amending directives

Electromagnetic Compatibility Directive (EMC), 89/336/EEC and its amending directives

DENAN- Electrical Appliance and Material Safety Law

**Applicable harmonized standard(s) and/or normative document(s):**

EN 50082-1:1992 Electromagnetic compatibility - Generic immunity standard Part 1: Residential, commercial and light industry

EN 55011:1991- Group 1 Class B, Limits and methods of measurement of radio disturbance characteristics of industrial, scientific, and medical (ISM) radio-frequency equipment

EN 60335-1:1995 Specification for safety of household and similar electrical appliances, General requirements

EN 60335-2-29: Part 2, 1991 Safety of household and similar electrical appliances-Particular requirements for battery chargers

EN 61010-1: Safety requirements for electrical equipment for measurement, control, and laboratory use

**Authorized Signatories:**

ETS-Lindgren L.P.  
Bryan Sayler, General Manager

ETS-Lindgren L.P.  
James C. Psencik, Vice President of Engineering

The authorizing signatures on this Declaration of Conformity document authorizes ETS-Lindgren, L.P. to affix the CE mark to the indicated product. CE marks placed on these products will be distinct and visible. Other marks or inscriptions liable to be mistaken with the CE mark will not be affixed to these products.

ETS-Lindgren, L.P. has ensured that technical documentation shall remain available on premises for inspection and validation purposes for a period ending at least 10 years after the last product has been manufactured.



